#### **APPLICATIONS**

Use wherever pressurized tanks are needed in water systems applications.

#### **SPECIFICATIONS**

Shell: Heavy-gauge steel

Base: High-impact composite, ABS

Finish: Electrostatically applied, baked-on

polyester paint

**Water Cell:** One-piece seamless PVC, made from FDA listed material

Flange: Reinforced polypropylene

**Service Connection:** Reinforced polypropylene integral to flange

**Air Valve:** Rubber stem/brass body

Schrader valve assembly

**UV Valve Cover:** 

High-density polyethylene



ORDERING INFORMATION										
Catalog	Maximum Capacity Gal/Liter	Diameter* Inch/cm	Height Inch/cm	Length Inch/cm	Precharge PSI/kPa	Connection Size Female	Drawdown in Gallons/Liter			Weight
Number							20-40	30-50	40-60	lbs/kg
VERTICAL MODELS										
PS6-S02	6.0/22.7	12/30.5	16.1/40.9	-	40/276	3/4" NPT	2.2/8.3	1.8/6.8	1.6/6.0	18/8.2
PS19S-T02	19/72	20/40.6	21/53.3	-	40/276	1" NPT	6.9/26.1	5.8/21.9	5.0/18.9	45/20.4
PS19T-T02	19/72	16/40.6	27.5/70	-	40/276	1" NPT	6.9/26.1	5.8/21.9	5.0/18.9	40/18.1
PS32-T03	32/122	20/51	43/109	-	40/276	1" NPT	11.6/43.9	9.8/37.1	8.5/32.2	56/25.4
PS35-T05	35/133	16/40.6	33/84	-	40/276	1" NPT	12.7/48.1	10.7/40.5	9.3/35.2	66/29.9
PS50-T50	50/189	20/51	32.5/83	-	40/276	1-1/4" NPT	18.3/69.3	15.5/58.7	13.4/50.7	84/38.1
PS62-T51	62/235	24/61	39.5/100	-	40/276	1-1/4" NPT	21.4/81.0	18.3/69.3	16.0/60.6	112/50.8
PS85-T52	85/322	24/61	51/130	-	40/276	1-1/4" NPT	30/113.6	26/98.4	22/83.3	124/56.2
PS119-TR50	119/450	24/61	68/173	-	40/276	1-1/4" NPT	41.3/156.3	35.4/134.0	31.0/117.3	140/63.5
IN-LINE VERT	ICAL MODELS									
PS2-S01	2.0/7.6	8.4/21.3	12.6/32.0	-	20/137.8	3/4" NPTM	0.7/2.65	0.6 /2.2	NA	12.6/5.7
PS5-S02	5.0/18.9	10.6/26.9	16.2/41.1	-	30/206.8	3/4" NPTM	2.2/8.3	1.8/6.8	1.8/6.8	16.2/7.3
HORIZONTAL MODELS										
PS6H-S05	6.0/22.7	12/30.5	13.8/35.0	16/40.6	40/276	3/4" NPT	2.2/8.3	1.8/6.8	1.6/6.0	22/10
PS19H-S00	19/72	16/40.6	17.5/44.5	28/71.1	40/276	1" NPT	6.9/26.1	5.8/21.9	5.0/18.9	40/18

<sup>\*</sup>Subject to change without notice.

Maximum Liquid Temperature: 120°F (49°C) Maximum External (Ambient) Temperature: 125°F (52°C)



Maximum Operating Pressure = 100 PSI

#### **FEATURES**

#### **Heavy-Gauge Metal Construction:**

Sturdy "welded wrapper and head design." Built to last.

**Polyester Paint Finish:** Electrostatically powder-painted, then oven-baked for a smooth high-gloss, appliance-quality finish. Resists corrosion.

#### **Elongated, Seamless Water Cell:**

- Controlled 2-dimensional cell expansion.
- Rugged, seamless "water cell" prevents the most common cause of tank failure – "waterlogging."
- Water never touches the steel tank material.
- Translucent bag material facilitates manufacturing quality control inspection.

#### Composite Sealing Flange:

- Corrosion-resistant.
- Integral O-ring groove better traps the water cell's sealing ring.
- Reinforcing ribs strengthen and maintain a flat smooth sealing surface.

**Integral Standpipe:** Keeps the water cell standing erect, promoting complete flushing of the water entering/exiting the tank.

**Nitrogen-Rich Precharge:** Decreases air permeation three to four times over straight air precharge.

**40 PSI Precharge:** Ready for use with 40/60 pressure range systems. Enables installer to reduce pressure depending on pressure switch setting.

**Sturdy Base:** Tested-tough composite construction.

#### Tank Sizing Rule

# Size tank for one gallon of drawdown for each gallon per minute at pump capacity.

Example: For a 1 HP, 20 GPM unit pumping 20 gallons per minute on a 30-50 pressure switch setting, the properly sized Pro-Source® tank is a PS85-T52 which has a 26 gallon drawdown.

CHART A									
Tank Selection Chart									
<b></b>	SYSTEM PRESSURE SWITCH SETTING – PSI								
Pump GPM	20	-40	30-	-50	40-60				
	Runtimes								
	1 Minute	2 Minute	1 Minute	2 Minute	1 Minute	2 Minute			
5	PS19T	PS32	PS19T	PS35	PS19T	PS50			
7.5	PS32	PS50	PS32	PS50	PS32	PS62			
10	PS32	PS62	PS35	PS85	PS50	PS85			
12.5	PS35	PS85	PS50	PS85	PS50	PS119			
15	PS50	PS85	PS50	PS119	PS62	PS119			
20	PS62	PS119	PS85	PS85 (2)	PS85	PS85 (2)			
30	PS85	PS85 (2)	PS119	PS119 + PS85	PS119	PS119 (2)			
30	-	-	PS119	PS119 + PS85	PS119	PS119 (2)			
50	PS62 + PS85	PS85 (3)	PS85 (2)	PS119 (3)	PS85 + PS119	PS119 (3) + PS50			

Note: Drawdown will be affected by operating temperature of the system, accuracy of the pressure switch and gauge, the actual precharge pressure, and rate of fill.

Pumps installed with a Pro-Source® tank require a 100 PSI relief valve. Relief valve must be capable of relieving entire flow of pump at relief pressure.

CHART B										
Drawdown Volume Multiplier* (Approx.)										
Pump Off	PUMP START PRESSURE – PSI									
Pressure PSI	10	20	30	40	50	60	70	80		
20	0.26									
30	0.41	0.22								
40		0.37	0.18							
50		0.46	0.31	0.15						
60			0.40	0.27	0.13					
70			0.47	0.35	0.24	0.12				
80				0.42	0.32	0.21	0.11			
90				0.48	0.38	0.29	0.19	0.10		
100			·		0.44	0.35	0.26	0.17		

<sup>\*</sup>Utilize this chart if proper selection cannot be made using Chart A. Drawdown based on Boyle's Law.

 $\textbf{PROCEDURE:} \quad 1. \ Identify \ drawdown \ multiplier \ relating \ to \ specific \ application.$ 

2. Insert multiplier (X) into the following formula:

Pump GPM x Min Runtime
Multiplier (X)

.24 (factor) from Chart B =

**EXAMPLE:** 


Minimum Tank Capacity Required

An example of a 20 GPM pump with a minimum runtime of 1 minute, installed on a 50-70 PSIG system pressure range: 20 GPM x 1 minute 83.3 minimum U.S. gal.

83.3 minimum U.S. gal. tank capacity required

Referring to "Ordering Information" chart, the model PS85-T52 has the closest U.S. gallon capacity that is greater or equal to the minimum volume requirement of  $83.3\,U.S.$  gallons.


#### **OPERATING CYCLE**




Separator is completely empty:

 A new cycle is ready to begin.


 Simple, positive action produces maximum drawdown on every cycle.



2. Water begins to enter the tank: Air is compressed around the water separator as it fills with water.



**3. Pump-up cycle completed:** Air is now compressed to the cut-off setting of pressure switch.



4. Water is being drawn from the tank: Compressed air in the tank forces water out of the separator.

#### **ACCESSORIES**



PKG 198 Universal Jet Pump to Tank Bracket



PKG 111, PKG 112 or PKG 207 Jet Pump-to-Tank Mounting Pkg.

#### **ORDERING INFORMATION**

PKG 198 - Jet Pump Mounting Bracket

PKG 111 - Pump-to-Tank Fitting Package for composite jet pumps


PKG 112 - Pump-to-Tank Fitting Package for cast iron series jet pumps with composite fittings

PKG 207 - Pump-to-Tank Fitting Package for cast iron series jet pumps with galvanized fittings

#### **MULTIPLE TANK INSTALLATIONS**

Pro-Source® tanks can be connected together to increase the supply of usable water (drawdown). Two tanks of the same size will double the supply and three tanks will triple the supply. See Figures No. 1 and 2 for the typical installations of this kind.

3





FROM WELL PRESSURE SWITCH

FROM WELL PRESSURE SWITCH

Figure 2

#### **OUTLINE DIMENSIONS**








**Catalog Number** Discharge NPT Α В C D Ε F VERTICAL MODELS PS6-S02 3/4" 12.0 16.1 PS19T-T02 1" 16.1 15.5 2.0 27.8 3.9 PS32-T03 1" 15.5 43.0 16.1 2.0 2.3 1" PS19S-T02 20.1 15.5 2.0 21.5 2.3 1" PS35-T05 20.1 15.5 2.0 33.0 2.3 PS50-T50 1-1/4" 24.1 22.7 2.5 33.2 5.5 PS62-T51 1-1/4" 24.1 22.7 2.5 40.1 5.5 PS85-T52 1-1/4" 24.1 22.7 2.5 51.5 5.5 PS119-TR50 1-1/4" 24.1 22.7 2.5 68.6 5.5 IN-LINE VERTICAL MODELS PS2-S01 3/4" 18.4 12.6 PS5-S02 3/4" 10.6 16.2 **HORIZONTAL MODELS** PS6H 3/4" 12.1 16.9 6.9 10.0 13.3 6.1 PS19H 1" 16.2 26.6 12.5 17.5 13.8


Dimensions (in inches) are for estimating purposes only.

#### **SEQUENCE OF OPERATION**









### WATER CELL IS COMPLETELY EMPTY:

A new cycle is ready to begin. Simple, positive action produces maximum drawdown on every cycle.

WATER BEGINS TO ENTER THE TANK:

Air is compressed around the water cell as it fills with water.

PUMP-UP CYCLE COMPLETED:

Air is now compressed to the cut-off setting of pressure switch.

### WATER IS BEING DRAWN FROM THE

**TANK:** Compressed air in the tank forces water out of the water cell.

